



## REGULATORY COMPLIANCE

---

# REPORT EN 50160

CIRCUTOR QNA600 - Serial Number: 22343534530003

Record start date: 28/04/2025 00:00:00 (UTC+02)

Record end date: 04/05/2025 23:59:59 (UTC+02)

Circuit type: 3PH4W

Nominal Voltage: 230V (Low Voltage)

Nominal Frequency: 50 Hz

05 May 2025

-  
BY  
QNA600

CIRCUTOR SAU - Vial Sant Jordi s/n,  
08232 Viladecavalls, Barcelona (Spain)  
t. +34. 93 745 29 00 - info@circutor.com

## LIST OF CONTENTS

0. SUMMARY OF RESULTS .....	3
1. POWER FREQUENCY .....	4
2. SUPPLY VOLTAGE VARIATIONS .....	5
2.1. L-N Voltage Variations .....	5
2.2. L-L Voltage Variations .....	6
3. FLICKER SEVERITY .....	7
4. SUPPLY VOLTAGE UNBALANCE .....	8
5. VOLTAGE HARMONICS AND THD .....	9
5.1. L1-N Voltage Harmonics and THD .....	9
5.2. L2-N Voltage Harmonics and THD .....	10
5.3. L3-N Voltage Harmonics and THD .....	11
6. MAINS SIGNALLING VOLTAGE .....	13
7. VOLTAGE EVENTS .....	14
7.1. Dips .....	14
7.2. Swells .....	16
7.3. Interruptions .....	17
7.4. ITIC Curve .....	18

## 0. SUMMARY OF RESULTS

- Time Interval: 28/04/2025 00:00:00 (UTC+02) - 04/05/2025 23:59:59 (UTC+02)
- Device: CIRCUTOR QNA600
- Serial Number: 22343534530003
- Firmware: 1.11.0
- Measure Firmware: v1.2.28


Power Quality Parameter	EN 50160 Compliance	Remarks
Power Frequency	FAIL	Coverage: 99.9%
L-N Supply Voltage Variations	PASS	Coverage: 100.0%
L-L Supply Voltage Variations	PASS	Coverage: 100.0%
PLT Flicker Severity	FAIL	Coverage: 7.5%
Supply Voltage Unbalance	PASS	Coverage: 100.0%
L1-N Voltage Harmonics	PASS	Coverage: 100.0%
L1-N THD	PASS	Coverage: 100.0%
L2-N Voltage Harmonics	PASS	Coverage: 100.0%
L2-N THD	PASS	Coverage: 100.0%
L3-N Voltage Harmonics	PASS	Coverage: 100.0%
L3-N THD	PASS	Coverage: 100.0%
Mains Signalling Voltage	PASS	Coverage: 100.0%
Dips	-	Quantity: 3
Swells	-	Quantity: 0
Interruptions	-	Quantity: 9

## 1. POWER FREQUENCY


- Nominal Frequency: 50 Hz
- Parameter definition: Mean value of the fundamental frequency measured over 10 seconds.
- Limitation: For networks coupled by synchronous connections to an interconnected system.  
According to EN50160, frequency analysis period should be 1 year.

Requirement	Requested (% time)	Measured (% time)	Result
49.50Hz - 50.50Hz	99.5%	99.9%	PASS
47.00Hz - 52.00Hz	100.0%	99.9%	FAIL

Frequency Temporal Extract



Frequency Normal Distribution




## 2. SUPPLY VOLTAGE VARIATIONS

### 2.1. L-N Voltage Variations


- Nominal Voltage: 230V
- Parameter definition: Supply voltage RMS values averaged over 10 min.
- Limitation: For networks coupled by synchronous connections to an interconnected system. Interruption intervals excluded. According to EN50160, voltage variations analysis period should be 1 week.

Requirement	Requested (% values)	L1 Voltage (% values)	L2 Voltage (% values)	L3 Voltage (% values)	Result
207V - 253V	95.0%	100.0%	100.0%	100.0%	PASS
195V - 253V	100.0%	100.0%	100.0%	100.0%	PASS

Voltage Variations Temporal Extract



Voltage Variations Normal Distribution




## 2.2. L-L Voltage Variations


- Nominal Voltage: 398V
- Parameter definition: Supply voltage RMS values averaged over 10 min.
- Limitation: For networks coupled by synchronous connections to an interconnected system. Interruption intervals excluded. According to EN50160, voltage variations analysis period should be 1 week.

Requirement	Requested (% values)	L12 Voltage (% values)	L23 Voltage (% values)	L31 Voltage (% values)	Result
358V - 438V	95.0%	100.0%	100.0%	100.0%	PASS
338V - 438V	100.0%	100.0%	100.0%	100.0%	PASS

Voltage Variations Temporal Extract





Voltage Variations Normal Distribution



### 3. FLICKER SEVERITY

- Parameter definition: Long term flicker severity PI<sub>t</sub> due to voltage fluctuations (2h intervals).
- Limitation: According to EN50160, flicker analysis period should be 1 week.

Requirement	Requested (% time)	L1 PI <sub>t</sub> (% time)	L2 PI <sub>t</sub> (% time)	L3 PI <sub>t</sub> (% time)	Result
PI <sub>t</sub> ≤ 1	95.0%	7.5%	7.5%	7.5%	FAIL




#### 4. SUPPLY VOLTAGE UNBALANCE


- Parameter definition: RMS values of the negative sequence  $U_2$  relative to the positive sequence  $U_1$ , averaged over 10 min.
- Limitation: According to EN50160, voltage unbalance analysis period should be 1 week.

Requirement	Requested (% values)	Measured (% values)	Result
0% - 2% ( $u_2$ )	95.0%	100.0%	PASS

Voltage Unbalance Temporal Extract



Voltage Unbalance Normal Distribution



## 5. VOLTAGE HARMONICS AND THD

### 5.1. L1-N Voltage Harmonics and THD

- Parameter definition: Harmonic voltage RMS values averaged over 10 min.
- Limitation: According to EN50160, harmonics analysis period should be 1 week.

Even Harmonics					Odd Harmonics				
Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result	Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result
H <sub>2</sub>	0% - 2.00%	95.0%	100.0%	PASS	H <sub>3</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>4</sub>	0% - 1.00%	95.0%	100.0%	PASS	H <sub>5</sub>	0% - 6.00%	95.0%	100.0%	PASS
H <sub>6</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>7</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>8</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>9</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>10</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>11</sub>	0% - 3.50%	95.0%	100.0%	PASS
H <sub>12</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>13</sub>	0% - 3.00%	95.0%	100.0%	PASS
H <sub>14</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>15</sub>	0% - 1.00%	95.0%	100.0%	PASS
H <sub>16</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>17</sub>	0% - 2.00%	95.0%	100.0%	PASS
H <sub>18</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>19</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>20</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>21</sub>	0% - 0.75%	95.0%	100.0%	PASS
H <sub>22</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>23</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>24</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>25</sub>	0% - 1.50%	95.0%	100.0%	PASS

#### THD

Requirement	Requested (% values)	Measured (% values)	Result
<= 8.00%	100.0%	100.0%	PASS

## 5.2. L2-N Voltage Harmonics and THD

- Parameter definition: Harmonic voltage RMS values averaged over 10 min.
- Limitation: According to EN50160, harmonics analysis period should be 1 week.

Even Harmonics					Odd Harmonics				
Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result	Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result
H <sub>2</sub>	0% - 2.00%	95.0%	100.0%	PASS	H <sub>3</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>4</sub>	0% - 1.00%	95.0%	100.0%	PASS	H <sub>5</sub>	0% - 6.00%	95.0%	100.0%	PASS
H <sub>6</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>7</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>8</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>9</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>10</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>11</sub>	0% - 3.50%	95.0%	100.0%	PASS
H <sub>12</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>13</sub>	0% - 3.00%	95.0%	100.0%	PASS
H <sub>14</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>15</sub>	0% - 1.00%	95.0%	100.0%	PASS
H <sub>16</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>17</sub>	0% - 2.00%	95.0%	100.0%	PASS
H <sub>18</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>19</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>20</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>21</sub>	0% - 0.75%	95.0%	100.0%	PASS
H <sub>22</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>23</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>24</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>25</sub>	0% - 1.50%	95.0%	100.0%	PASS

THD			
Requirement	Requested (% values)	Measured (% values)	Result
<= 8.00%	100.0%	100.0%	PASS


### 5.3. L3-N Voltage Harmonics and THD

- Parameter definition: Harmonic voltage RMS values averaged over 10 min.
- Limitation: According to EN50160, harmonics analysis period should be 1 week.


Even Harmonics					Odd Harmonics				
Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result	Order h	Requirement (%Uf)	Requested (% values)	Measured (% values)	Result
H <sub>2</sub>	0% - 2.00%	95.0%	100.0%	PASS	H <sub>3</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>4</sub>	0% - 1.00%	95.0%	100.0%	PASS	H <sub>5</sub>	0% - 6.00%	95.0%	100.0%	PASS
H <sub>6</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>7</sub>	0% - 5.00%	95.0%	100.0%	PASS
H <sub>8</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>9</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>10</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>11</sub>	0% - 3.50%	95.0%	100.0%	PASS
H <sub>12</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>13</sub>	0% - 3.00%	95.0%	100.0%	PASS
H <sub>14</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>15</sub>	0% - 1.00%	95.0%	100.0%	PASS
H <sub>16</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>17</sub>	0% - 2.00%	95.0%	100.0%	PASS
H <sub>18</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>19</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>20</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>21</sub>	0% - 0.75%	95.0%	100.0%	PASS
H <sub>22</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>23</sub>	0% - 1.50%	95.0%	100.0%	PASS
H <sub>24</sub>	0% - 0.50%	95.0%	100.0%	PASS	H <sub>25</sub>	0% - 1.50%	95.0%	100.0%	PASS

THD			
Requirement	Requested (% values)	Measured (% values)	Result
<= 8.00%	100.0%	100.0%	PASS

THD Temporal Extract



THD Normal Distribution



### 6. MAINS SIGNALLING VOLTAGE

- Nominal Voltage: 230V
- Signalling Frequency: 1060.0 Hz
- Parameter definition: Data signals voltage RMS values averaged over 3s.

Requirement	Requested (% time)	L1 Signalling (% time)	L2 Signalling (% time)	L3 Signalling (% time)	Result
0V - 11V	99.0%	100.0%	100.0%	100.0%	PASS

## 7. VOLTAGE EVENTS

### 7.1. Dips

- Nominal Voltage: 230V
- Parameter definition: On Polyphase systems, a Dip begins when the Urms voltage of one or more channels falls below the Dip threshold (90% Vnom) and ends when the Urms voltage of all measured channels is equal to, or above, the Dip threshold plus the hysteresis voltage (2% Vnom).  
Each Dip is characterized by the min Urms value reached (u: Residual Voltage, in % Vnom) and its duration.
- Limitation: According to EN 50160, Polyphase evaluation should be used to identify Dips

#### - L1-N Dips

Residual Voltage (u: % Vnom)	Occurrences					
	10ms <= t <= 0.2s	0.2s < t <= 0.5s	0.5s < t <= 1s	1s < t <= 5s	5s < t <= 60s	60s < t
80 <= u < 90	1	0	0	0	0	0
70 <= u < 80	0	1	1	0	0	0
40 <= u < 70	0	0	0	0	0	0
5 <= u < 40	0	0	0	0	0	0
u < 5	0	0	0	0	0	0

(DEVICE IMMUNITY REQUIRED: Beyond Class 3)

Phases	Date	Time	Details	
			Residual Voltage	Duration
L1-N	28/04/2025	12:33:20.076	73.73 %	594 ms
L1-N	28/04/2025	12:33:21.149	77.66 %	286 ms
L1-N	29/04/2025	01:03:05.656	88.51 %	70 ms

#### - L2-N Dips

Residual Voltage (u: % Vnom)	Occurrences					
	10ms <= t <= 0.2s	0.2s < t <= 0.5s	0.5s < t <= 1s	1s < t <= 5s	5s < t <= 60s	60s < t
80 <= u < 90	0	0	0	0	0	0
70 <= u < 80	0	1	1	0	0	0

$40 \leq u < 70$	0	0	0	0	0	0
$5 \leq u < 40$	0	0	0	0	0	0
$u < 5$	0	0	0	0	0	0

(DEVICE IMMUNITY REQUIRED: Beyond Class 3)

Details				
Phases	Date	Time	Residual Voltage	Duration
L2-N	28/04/2025	12:33:20.083	73.79 %	584 ms
L2-N	28/04/2025	12:33:21.156	77.96 %	276 ms

### - L3-N Dips

Residual Voltage (u: % Vnom)	Occurrences					
	$10\text{ms} \leq t \leq 0.2\text{s}$	$0.2\text{s} < t \leq 0.5\text{s}$	$0.5\text{s} < t \leq 1\text{s}$	$1\text{s} < t \leq 5\text{s}$	$5\text{s} < t \leq 60\text{s}$	$60\text{s} < t$
$80 \leq u < 90$	0	0	0	0	0	0
$70 \leq u < 80$	0	1	1	0	0	0
$40 \leq u < 70$	0	0	0	0	0	0
$5 \leq u < 40$	0	0	0	0	0	0
$u < 5$	0	0	0	0	0	0

(DEVICE IMMUNITY REQUIRED: Beyond Class 3)

Details				
Phases	Date	Time	Residual Voltage	Duration
L3-N	28/04/2025	12:33:20.090	74.56 %	574 ms
L3-N	28/04/2025	12:33:21.159	78.83 %	269 ms

## 7.2. Swells

- Nominal Voltage: 230V
- Parameter definition: On Polyphase systems, a Swell begins when the Urms voltage of one or more channels rises above the Swell threshold (110% Vnom) and ends when the Urms voltage of all measured channels is equal to, or below, the Swell threshold minus the hysteresis voltage (2% Vnom).  
Each Swell is characterized by the max Urms value reached (u: Swell Voltage, in % Vnom) and its duration.
- Limitation: According to EN 50160, Polyphase evaluation should be used to identify Swells

### - L1-N Swells

NO SWELLS HAVE OCCURRED ON SELECTED DATES.

### - L2-N Swells

NO SWELLS HAVE OCCURRED ON SELECTED DATES.

### - L3-N Swells


NO SWELLS HAVE OCCURRED ON SELECTED DATES.

### 7.3. Interruptions

- Nominal Voltage: 230V
- Parameter definition: On Polyphase systems, an Interruption takes place when the Urms voltage falls below 5% Vnom on all channels. Otherwise, it's considered to be a Dip.  
An interruption is characterized by its duration.
- Limitation: According to EN 50160, Polyphase evaluation should be used to identify Interruptions  
According to EN 50160, Interrupt threshold should be 5% of the Nominal Voltage.

Phases	Date	Time	Duration	Type
L2-N	28/04/2025	12:33:23.995	311 ms	Short
L1-N	28/04/2025	12:33:23.998	301 ms	Short
L3-N	28/04/2025	12:33:24.002	301 ms	Short
L2-N	28/04/2025	12:33:24.451	134 ms	Short
L3-N	28/04/2025	12:33:24.459	122 ms	Short
L1-N	28/04/2025	12:33:24.477	111 ms	Short
	28/04/2025	12:33:25.270	41303176 ms	Long
	28/04/2025	12:33:25.274	41303176 ms	Long
	28/04/2025	12:33:25.277	41303172 ms	Long

7.4. ITIC Curve



3 QUALITY EVENTS ARE NOT SHOWN IN THE ITIC CURVE BECAUSE THEY ARE OUT OF SCOPE OF IT (DURATION > 100s) .