

CODES FOR TYPE OF WIRING					
D	E	F	G	H	O (Other - please state)
Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables	

Page of

forms shown in Appendix 6 of BS 7671
Ascertiva Group © Copyright The Electrical Safety Council (July 2011)

See next page for Schedule of Test Results

The page number for each additional schedule should be inserted at the foot of the schedule, together with the total number of pages comprising the certificate or report (e.g. page 6 of 7).

There is a tendency to overlook the need to record circuit details and test results for distribution circuits (commonly referred to as 'sub-mains'), where such circuits form part of an installation. For example, where the switchboard at the origin of an installation incorporates a number of fused-switches feeding distribution circuits to remote distribution boards, the information relating to those distribution circuits will need to be recorded on a Schedule of Circuit Details and a Schedule of Test Results. Such additional schedules are also required for the distribution circuit where a main switch at the origin of an installation feeds a single, remote distribution board.

The Electrical Installation Certificate or Electrical Installation Condition Report must also include an additional Schedule of Circuit Details and Schedule of Test Results for each of the distribution boards, including their final circuits.

Chapter

7

The Schedule of Items Inspected for new installation work

- PURPOSE OF INSPECTION
- SAFETY
- INSPECTION OF NEW INSTALLATION WORK
- THE SEQUENCE OF INSPECTIONS
- PROTECTIVE MEASURES AGAINST ELECTRIC SHOCK
- PROVISION OF BASIC AND FAULT PROTECTION MEASURES
- PROVISION OF BASIC PROTECTION MEASURES
- PROVISION OF FAULT PROTECTION MEASURES
- ADDITIONAL PROTECTION
- PREVENTION OF MUTUAL DETRIMENTAL INFLUENCE
- IDENTIFICATION
- CABLES AND CONDUCTORS
- GENERAL ITEMS